

LICENCE

No. 18874

Issued to:
Applicant:
Kabelwerk Eupen A.G.
Malmedyerstraat 9
4700 EUPEN
Belgium

Licensee:
Kabelwerk Eupen A.G.
Malmedyerstraat 9
4700 EUPEN
Belgium

Product : conduit systems for cable management
Trade name(s) : EUCAVOLT HF
Type(s)/model(s) : ICTA 3352

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 7

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 22/04/2014

ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	:	conduit systems for cable management
Trade name(s)	:	EUCAVOLT HF
Type(s)/Model(s)	:	ICTA 3352
type of conduit (1)	:	non-metallic
type of conduit (2)	:	classification 33521240/010
type of conduit (3)	:	plain
method of connection	:	non-threadable
resistance to compression	:	medium
resistance to impact	:	medium
resistance to bending	:	rigid
lower temperature range	:	-45°C
upper maximum temperature range	:	+90°C
electrical characteristics	:	with electrical insulating
resistance to flame propagation	:	non-flame propagation
diameter(s)	:	16, 20, 25, 32, 40, 50 & 63 mm
colour(s)	:	grey

Additional information

Halogen free

TESTS**Test requirements**

NBN EN 60423 based on EN 60423:1994

NBN EN 61386-1 based on EN 61386-1:2008

NBN EN 61386-21 based on EN 61386-21:2004 + A11:2011

Test results

The test results are laid down in certification file ref.606610/01

Remarks

This certificate is based on certificate ref. CCA/DE 13828 and VDE 40001765 and test report(s) ref. 2658-5410-0021/A406PX


Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanuttó Luigi - 22/04/2014

Department Manager,
Product Certification :

Certification Manager :

 2014-04-22