

LICENCE

No. 12827 - Issue No 2

Issued to:
Applicant:
Kabelwerk Eupen A.G.
Malmedyerstraat 9
4700 EUPEN
Belgium



Licensee:
Kabelwerk Eupen A.G.
Malmedyerstraat 9
4700 EUPEN
Belgium

Product : conduit systems for cable management
Trade name(s) : EUPEN
Type(s)/model(s) : DN16, DN20, DN25, DN32, DN40, DN50, Versterkt-Renforcé

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 7


SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 22/12/2009

Ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	conduit systems for cable management
Trade name(s)	:	EUPEN
Type(s)/Model(s)	:	DN16, DN20, DN25, DN32, DN40, DN50, Versterkt-Renforcé
type of conduit (1)	:	non-metallic
type of conduit (2)	:	classification 3331
type of conduit (3)	:	plain
method of connection	:	non-threadable
resistance to compression	:	medium
resistance to impact	:	medium
resistance to bending	:	pliable
lower temperature range	:	-15°C
upper maximum temperature range	:	+60°C
electrical characteristics	:	with electrical insulating
resistance to flame propagation	:	non-flame propagation
colour(s)	:	grey - RAL 7016

TESTS

Test requirements

NBN EN 60423 based on EN 60423:1994
NBN EN 61386-1 based on EN 61386-1:2004
NBN EN 61386-21 based on EN 61386-21:2004

Test results

The test results are laid down in certification file ref.574814/01

Remarks

This certificate is based on test report(s) ref. Ro/QSE/SB - 10.09.2002

Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 22/12/2009

Department Manager,
Product Certification :

Certification Manager :

FACTORY LOCATION(S)

Kabelwerk Eupen A.G.
Hütte 66
4700 EUPEN
Belgium